

Toppe Consultants, Inc.
Architects Planners

210 Fourteenth Avenue North
St. Petersburg, Florida 33701
John@ToppeArchitects.com
727-823-1220 voice
727-823-7848 fax
AA26000849

Palm Harbor Library
Renovation Project
November 16, 2007

ADDENDUM NUMBER THREE

General Contract Bidders are reminded, in accordance with the Instructions to Bidders, that only those bids from Bidders who are pre-qualified with Pinellas County in the amount that equals or exceeds their bid prior to the opening of bids will be considered. **This is a pre-qualification project requiring Bidders to be prequalified for General Construction.**

Bids are due at 2:00 PM on Tuesday, November 20, 2007.

The following modifies, revises or clarifies the Plans or other Contract Documents as follows. The Bidder shall acknowledge that his proposal is based on the plans and specifications as modified herein by indicating same in the space provided on the Proposal and Bid form.

Item 3.01 Specifications Section 10430 - Signs:

1. **Paragraph 2.1.A:** Add, "Equivalent products by local manufacturers will be accepted."
2. **Paragraph 2.3.B:** Delete and substitute the following:
 - B. "Sign Schedule: Provide the following signs as listed below, manufacturer's standard colors and fonts to be selected by architect:
 1. Four (4) : 8" x 8" (restrooms with ADA graphic identification): Men, Women, Family Toilet, and Staff Toilet (One each).
 2. Three (3): 8"x 8" (warning with ADA graphic identification): Electrical (two required), Janitor (one required)"

**Item 3.02 Specifications Section 16720 - Addressable Fire Alarm System,
Paragraph 1.3.C:** Add manufacturer "GE Security, Inc."

Item 3.03 Drawing E-201 – Lighting Plan:

1. **Half-shaded light fixtures:** Add Note, "Provide emergency ballast for all half-shaded light fixtures indicated on plans. Emergency ballast shall be Bodine B-50 or equivalent."
2. **Fixture Type J:** Add note, "Light fixture type J indicated in rooms 111, 113, and 114 shall be a fluorescent surface wrap light fixture, Daybrite #SWN232 or equivalent."
3. **Light Fixtures, Storage Room 124:** change to "Type A" in lieu of "Type B" as indicated on plans.
4. **Light Fixtures, Teen's Library Room 134:** Add note, "Linear light fixtures in soffits shall remain. Contractor shall retrofit per general note, this sheet."
5. **Light Fixtures in soffits and gypsum wall board ceilings:** Note that all existing 1' x 4' fixtures in soffits and GWB ceilings are to remain and be retrofitted per general notes this sheet. All existing retrofitted fixtures shall receive new louvers.

End of Addendum Number Three